

ADDENDUM NO. 1
COMPETITIVE SEALED BID
CITY OF DICKINSON, TEXAS



**CITY OF DICKINSON ANNUAL CONTRACT FOR
PURCHASE AND DELIVERY OF GASOLINE AND DIESEL
COMPETITIVE SEALED BID # 1210-04**

**BID OPENING DATE:
OCTOBER 28, 2011**

ADDENDUM NO. 1

CITY OF DICKINSON ANNUAL CONTRACT FOR PURCHASE AND DELIVERY OF GASOLINE AND DIESEL COMPETITIVE SEALED BID # 1210-04

TECHNICAL SPECIFICATIONS

Remove and replace Page 33 of the Technical Specifications with the attached page marked **“Addendum No. 1.”**

<u>Item</u>	<u>Test Method</u>	<u>Min</u>	<u>Max</u>
Gravity API @ 60°F	ASTM D-287 or ASTM D-1298		Report
Corrosion 3Hrs/122°F	ASTM D-130		1.00
Gum mg/100ml After wash	ASTM D-381		4.00
Lead gm/gal/origin	ASTM D-3237 or equal		0.03
Doctor Test	ASTM D-235		Neg.
Sulpher Wt %	ASTM D-1266		0.10%
Phosphorous gm/gal	ASTM D-3231		0.004
Oxidation Stability/mins	ASTM D-525	240	
Octane R + M/2		92.0 <u>87.0</u>	
Benzene Wt %	ASTM D-3606 or ASTM D-4053		4.90
Oxygen Wt %			2.70

1. The supplier shall ensure that the gasoline furnished shall meet the current ASTM D-4814 guidelines and EPA regulations for volatility specifications. In the event of a conflict between the specifications described above, the federal regulatory specifications shall take precedent.